

# PVC SCHEDULE 80

## Specifications

### Injection Molded PVC SCH 80 Fittings:

- **ASTM D2464** - Threaded Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80.
- **ASTM D2467** - Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80.
- **ASTM D1784** - Rigid Poly (Vinyl Chloride) (PVC) Compounds and Chlorinated Poly (Vinyl Chloride) (CPVC) Compounds.
- **ASTM F1970** – Standard Specification for Special Engineered Fittings, Appurtenances or Valves for use in Poly (Vinyl Chloride) (PVC) or Chlorinated Poly (Vinyl Chloride) (CPVC) Systems.



### Reference

Complete line: 1/4" to 12"



### PVC SCH 80 Information:

---

NSF APPROVED FOR POTABLE WATER SERVICES.

---

DO NOT USE FITTINGS FOR COMPRESSED AIR OR GASES.

---

DO NOT TEST PVC PIPING SYSTEMS WITH COMPRESSED AIR OR GASES.

---

DO NOT USE FITTINGS WITH LIQUIDS NOT RECOMMENDED BY DURA/TIGRE.

---

MODIFICATION OF FITTINGS VOIDS THE WARRANTY.

---

SPECS SUBJECT TO CHANGE WITHOUT NOTICE.

---

#### Dura Plastics

customerservice@duraplastics.com  
1.951.845.3161  
www.duraplastics.com

#### Tigre USA

customerservice@tigre.com  
1. 608.754.4554  
www.tigreusa.com/

